



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

May 24, 2007

CREST HOMES  
DAVID N. RICHTER  
437 N MAIN ST  
PO BOX 1218  
MIDDLEBURY IN 46540

CREST HOMES  
CMH MANUFACTURING  
RON KNEPP  
437 N MAIN ST  
PO BOX 1218  
MIDDLEBURY IN 46540

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: CREST HOMES  
Product Name: SINGLE FAMILY DWELLING  
Model Number(s): 6036-1068-1  
Product File No: 20070246

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2012.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 33 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum water supply fixture units (wsfu) on Type M copper tubing must not exceed 112.0 wsfu for 1-1/2-inch tubing, 62.0 wsfu for 1-1/2-inch tubing, 34.0 wsfu for 1-inch tubing, 18.0 wsfu for 3/4-inch tubing and 7.5 wsfu for 1/2-inch tubing.
- The maximum water supply fixture units (wsfu) on galvanized steel piping must not exceed 33.0 wsfu for 1-inch piping, 18.5 wsfu for 3/4-inch piping and 9.5 wsfu for 1/2-inch piping.
- The maximum water supply fixture units (wsfu) on Type L copper tubing must not exceed 31.0 wsfu for 1-inch tubing, 16.5 wsfu for 3/4-inch tubing and 6.5 wsfu for 1/2-inch tubing.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov